

# ATTESTATION OF CONFORMITY

Issued to:	HANTECH İKLİMLENDİRME SAN. TİC.A.Ş. Ziya Gökalp Mah. Süleyman Demirel Blv. No:7E / 138, Başakşehir - İstanbul, Türkiye
For the product:	Split Type Air Conditioner
Trade name:	HANTECH
Type/Model:	Indoor unit / outdoor unit: HNT-BN18VMCL/I / HNT-BN18VMCL/O, HNT-BN24VMCL/I / HNT-BN24VMCL/O
Ratings:	220-240 V~, 50 Hz, Class I, R32, IPX4 for outdoor unit, HNT-BN18VMCL/I / HNT-BN18VMCL/O: Cooling mode: 2350 W, 12,0 A, Heating mode: 2550 W, 13,0 A, HNT-BN24VMCL/I / HNT-BN24VMCL/O: Cooling mode: 2800 W, 12,6 A, Heating mode: 3000 W, 13,4 A
Manufactured by:	TCL Air conditioner (Zhong Shan) Co., Ltd. No.59, Nantou Road West, Nantou, Zhongshan, Guangdong, China
Subject:	Complete evaluation of electrical system of the appliances
Requirements:	EN 60335-1:2012 + A11:2014 + A13:2017 + A1:2019 + A14:2019 + A2:2019 + A15:2021 EN 60335-2-40:2003 + A11:2004 + A12:2005 + A1:2006 + A2:2009 + A13:2012 EN 62233:2008

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a test file / test report no 4931812.50.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of this production with the specimen tested by DEKRA is not the responsibility of DEKRA.

This document does not authorize the use of any DEKRA approved mark.

Arnhem, 15 January 2025

Number: 4931812.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.,  
Guangzhou Branch

May Liu  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Testing and Certification (Shanghai) Ltd., Guangzhou Branch  
Block 5, No.3, Qiyun Road, Huangpu District, Guangzhou, Guangdong, China  
T +86 20 6661 2000 F +86 20 6661 2001 www.dekra-product-safety.com